

Office of Environmental Public Health Sciences Washington State Department of Health 243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: FederalWay

School Name: Lakeland Elementary

School Code: 2841

School Address: 35827 32nd Ave South, Auburn Washington 98001

Number of Samples Collected: 54

**Date Collected:** 04/05/2019

F	Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
	22296	other	other		<1	04/26/2019	02569, 6:49 AM
	22297	${\bf FirstDraw}$	Bubbler	Room 113	<1	04/26/2019	
	22298	FirstDraw	Tap	Room 113	4	04/26/2019	Water from all classrooms taps use a mixing valve
	22299	${\bf FirstDraw}$	Bubbler	Room 112	<1	04/26/2019	
	22300	FirstDraw	Tap	Room 112	2	04/26/2019	No Aerator
	22301	${\bf FirstDraw}$	Bubbler	Room 114	<1	04/26/2019	
	22302	FirstDraw	Tap	Room 114	6	04/26/2019	
	22303	FirstDraw	Bubbler	Hallway (Outside Room 114)	<1	04/26/2019	Left Side, button came off
	22304	FirstDraw	Bubbler	Hallway Fountain Outside Room 114	<1	04/26/2019	Right Side
	22305	${\bf FirstDraw}$	Bubbler	Room 117	3	04/26/2019	
	22306	FirstDraw	Tap	Room 117	35	04/26/2019	
	22307	${\bf FirstDraw}$	Bubbler	Cafeteria	<1	04/26/2019	Left Side
	22308	FirstDraw	Bubbler	Cafeteria	<1	04/26/2019	Right Side
	22309	FirstDraw	Тар	Kitchen, Left Tap	1	04/26/2019	Tap has mineral buildup, apples washed in kitchen
	22310	FirstDraw	Tap	Kitchen, Right Tap	19	06/20/2019	Tap has mineral buildup, water discolored
	22311	${\bf FirstDraw}$	Bubbler	Room 120	<1	04/26/2019	
	22312	FirstDraw	Tap	Room 120	1	04/26/2019	No Aerator
	22313	${\bf FirstDraw}$	Bubbler	Room 121	<1	04/26/2019	
	22314	FirstDraw	Tap	Room 121	2	04/26/2019	
	22315	${\bf FirstDraw}$	Bubbler	Room 122	<1	04/26/2019	
	22316	FirstDraw	Tap	Room 122	6	04/26/2019	

(continued)

Program ID	Sample Type	Description	Location	$egin{array}{c}  ext{Lead} \  ext{Results} \  ext{(ppb)} \end{array}$	Analysis Date	Comments
22317	FirstDraw	Bubbler	Room 123	<1	04/26/2019	
22318	FirstDraw	Tap	Room 123	36	04/26/2019	
22319	FirstDraw	Bubbler	Room 124	4	04/26/2019	
22320	FirstDraw	Тар	Room 124	1	04/26/2019	Tap Base Loose
22321	FirstDraw	Тар	Room 102, Health Room	16	04/26/2019	
22322	FirstDraw	Bubbler	Room 160	1	04/26/2019	
22323	FirstDraw	Tap	Room 160	<1	04/26/2019	Tap Base Loose
22324	FirstDraw	Bubbler	Room 159	10	04/26/2019	
22325	FirstDraw	Тар	Room 159	2	04/26/2019	Fountains outside Room 159 donâ t produce enough water for collection
22326	FirstDraw	Bubbler	Room 131 A	6	04/26/2019	
22327	FirstDraw	Tap	Room 131A	3	04/26/2019	
22328	FirstDraw	Bubbler	Room 132	3	04/26/2019	
22329	${\bf FirstDraw}$	Tap	Room 132	4	04/26/2019	
22330	FirstDraw	Bubbler	Room 133	3	04/26/2019	
22331	FirstDraw	Tap	Room 133	3	04/26/2019	
22332	FirstDraw	Bubbler	Room 134	1	04/26/2019	
22333	FirstDraw	Tap	Room 134	12	04/26/2019	
22334	FirstDraw	Bubbler	Room 135	3	04/26/2019	
22335	FirstDraw	Tap	Room 135	7	04/26/2019	
22336	FirstDraw	Тар	Room 152, Workroom	5	04/26/2019	Bubbler doesnâ t work, No Aerator on tap
22337	FirstDraw	Bubbler	Room 146	8	04/26/2019	•
22338	FirstDraw	Тар	Room 146	1	04/26/2019	

(continued)

Program ID	Sample Type	Description	Location	$\begin{array}{c} \operatorname{Lead} \\ \operatorname{Results} \\ (\operatorname{ppb}) \end{array}$	Analysis Date	Comments
22339	${\bf FirstDraw}$	Bubbler	Room 145	<1	04/26/2019	
22340	FirstDraw	Tap	Room 145	<1	04/26/2019	
22341	FirstDraw	Bubbler	Room 144	<1	04/26/2019	Used this morning
22342	FirstDraw	Tap	Room 144	<1	04/26/2019	Used this morning
22343	${\bf FirstDraw}$	Bubbler	Room 143	5	04/26/2019	
22344	FirstDraw	Tap	Room 143	<1	04/26/2019	Tap Base Loose
22345	FirstDraw	Bubbler	Room 142	1	04/26/2019	
22346	FirstDraw	Tap	Room 142	111	06/20/2019	
22347	FirstDraw	Тар	Room 140, staff Lounge	<1	04/26/2019	Used this morning
22348	FirstDraw	Bubbler	Fountains near library	1	04/26/2019	Left Side
22349	FirstDraw	Bubbler	Fountains near library	<1	04/26/2019	Right Side